
PANEL SPECIFICATIONS:

- 1. THE PANEL IS MADE OF 2MM THICKNESS STEEL SHEET INCLUDING THE DOORS.
- 2. PANEL'S BOTTOM COVERED BY THREE PLATES EACH FABRICATED FROM 3MM THICKNESS STEEL SHEET.
- 3. THE PANEL IS POWDER COATED BY RAL 7038 FROM OUTSIDE AND RAL 9003 FROM INSIDE.
- 4. THE PANEL IS FABRICATED ACCORDING TO CLAUSE NO. 4.1 OF 31-TMSS-01.



LEGEND

1. ALL DIMENSIONS ARE IN MILLIMETER UNLESS

OUTSIDE AND RAL 9003 FROM INSIDE.

2. PANEL IS CONSTRUCTED ACCORDING TO 31-TMSS-01. 3. THE PANEL IS POWDER COATED BY RAL 7038 FROM

OTHERWISE NOTED.

GA: GENERAL ASSEMBLY LA: LIST OF APPARATUS M : REVENUE METER

> DRAWING NO. DRAWING CONTROL SHEET CD-320880

DRAWING TITLE

REFERENCE DRAWINGS

AS-BUILT BY DETAIL DESIGN 0 12/01 AM REV. DATE BY

الشركة السويية للكهرياء Saudi Electricity Company

DRAWN BY AM . CHECKED BY ____AS DATE STARTED ... OPR'G. DEPT.

APPROVAL/CERTIFICATION INFORMATION DOC NO. E-123456 REV NO. DO

8/8 8162, GA AND LA DRAWING METERING PANEL, 4 M, 3P4W ADDAD

WITHOUT CHANGE OVER CONTACTS


A C469 CD-320884 01 of 04 00

DESCRIPTION

METERING PANEL, FOUR METERS 3P4W 1(6)A WITHOUT CHANGE OVER CONTACTS



11131113/00



			PARTS LIST		
QTY	CAGE CODE	PART OR IDENTIFYING NO	NOMENCLATURE OR DESCRIPTION	MATERIAL / SPECIFICATION	ITEM
4	SE455	900-003524	ADDAD-4 CLO.2S , TOP ASSEMBLY, RS485 1(6)A	AEC, RIYADH	1
1		FR2H014014014N	FT-SWTCH KIT, 3	ABB RIYADH, KIT OF 3 FT-SWITCH, WITH SCREWS, COVER AND MOUNTING PLATE 2U	2
1		FR2H000014000N	FT-SWTCH KIT, 1	ABB RIYADH, KIT OF 1 FT-SWITCH, WITH SCREWS, COVER AND MOUNTING PLATE 2U	3
26		3031487	SPRING -CAGE FEED-THROUGH MODULAR TERMINAL BLOCK, ST6	PHOENIX	4
20		3031212	SPRING -CAGE FEED-THROUGH MODULAR TERMINAL BLOCK, ST2.5	PHOENIX	5
44		3046139	DISCONNECT TYPE SCREW CONNECTION FEED-THROUGH MODULAR TERMINAL BLOCK UT4-MT.	PHOENIX	6
44		0790462	DISCONNECT TYPE TERMINAL BLOCK OTTA 6-T-P/P	PHOENIX	7
5		3044102	SCREW CONNECTION TYPE FEED-THROUGH MODULAR TB UT4	PHOENIX	8
7		3044733	FEED-THROUGH MODULAR TERMINAL BLOCK 4 CONNECTIONS UTTB4-PV	PHOENIX	9
18		0309086	DISCONNECT TYPE TERMINAL BLOCK URTK/S-BEN	PHOENIX	10
4		25007	AC MCB, 3P4P 1A	SCHNEIDER, COOH, C CURVE, THREE PHASE 4 POLE, 1A	11
2		25855	AC MCB, 1P2P 6A	SCHNEIDER, C60H, B CURVE, SINGLE PHASE 2 POLE, 6A	12
1		25640	AC MCB, 1P1P 2A	SCHNEIDER, C60H, C CURVE, SINGLE PHASE 1 POLE, 2A	13
4		MGN61521	DC MCB, 2P 1A	SCHNEIDER, C32H, U CURVE, 2 POLE DC MCB, 1A	14
4		26924	AUXILIARY CONTACT, TYPE "OF"	SCHNEIDER,	15
1		01140.000	THERMOSTAT KTO 011, 0-60°C	STEGO, THERMOSTAT KTO 011, 0-60°C NORMALLY CLOSED AND CLIP FOR 35MM DIN RAIL	16
1		06020.000	ANTI CONDENSATION HEATER	STEGO, CS 060 SERIES, 150 WATT, 120-240 VAC	17
1		5822-1	DUPLEX RECEPTACLES 220VAC	SANA, RIYADH, 2POLE, 3WIRE, 20A 220V, IVORY.	18
1		3232-1	DUPLEX RECEPTACLES 110VAC	SANA, RIYADH, 2POLE, 3WIRE, 15A 127V, IVORY.	19
1		TPTE1-I	TELEPHONE JACK	SANA, RIYADH, RJ11, TELEPHONE JACK WALL PLATE	20
1		1X20 MODEL 2004 ELECTRONE OR 60620	LAMP 127VAC OR 220VAC	ALRAED, FLUORESCENT LAMP, 20W, 60HZ. 127VAC OR 220VAC PANEL LAMP -230VAC, 50Hz	21
2		Z15G1307 OR AZ7310	LIMIT SWITCH	HIGHLY LIMIT SWITCH 15A 125/220 VAC LIMIT SWITCH WITH 10A 250V AC MAX	22

NOTES

- 1. ALL DIMENSIONS ARE IN MILLIMETER UNLESS OTHERWISE NOTED.
- 2. PANEL IS CONSTRUCTED ACCORDING TO 31-TMSS-01.

LEGEND

GA: GENERAL ASSEMBLY LA: LIST OF APPARATUS

M : REVENUE METER

REFERENCE DRAWINGS DRAWING TITLE DRAWING NO. DRAWING CONTROL SHEET CD-320880

AS-BUILT BY. DETAIL DESIGN 0 12/01 AM REV. DATE BY DESCRIPTION

الشركة السهوية للكهرياء Saudi Electricity Company

DRAWN BY AM CHECKED BY AS DATE STARTED _____ OPR'G. DEPT. ___ ENG. DEPT. ..

THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION OF FOR ORDERING MATERIAL UNTIL CERTIFIED AND DATED DOC NO. E-123456 REV NO. DO

S/S 8162, QA AND LA DRAWING METERING PANEL, 4 M, 3P4W ADDAD

WITHOUT CHANGE OVER CONTACTS

RYADH SAUDI ARABIA
NDEX PLANT NO. DRAWING NUMBER SHEET NO. REV. NO.
A C469 CD-320884 03 0F 04 00 11131113/00

unced Electronics Co

AEC

